GOVERNMENT OF WEST BENGAL OFFICE OF THE DIVISIONAL FIRE OFFICER WEST BENGAL FIRE & EMERGENCY SERVICES

Memo No: IND/WB/FES/20192020/70937

DATE: 22/10/2019

From:

The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To:

DAV PUBLIC SCHOOL

EXISTING SCHOOL BUILDING WITH BLOCK 1, BLOCK 2 AND ALSO SINGLE STORIED OFFICE BUILDING IN FAVOUR OF DAV PUBLIC SCHOOL OVER PLOT NO. 29, JL NO. 38, MOUZA- RANGAMETA, PS- SALANPUR, PASCHIM BARDHAMAN. Asansol F.S., Salanpur PS, Paschim Bardhaman - 713335.

Sub: Fire Safety Certificate IN FAVOUR OF DAV PUBLIC SCHOOL for the occupancy of an existing construction of BLOCK A G + 2 storied building AND BLOCK B G + 2 storied building AND ALSO SINGLE STORIED OFFICE BUILDING under group Educational at the premises no OVER PLOT NO. 29, JL NO. 38, MOUZA- RANGAMETA, PS- SALANPUR, PASCHIM BARDHAMAN., Salanpur PS, Paschim Bardhaman – 713335

This is in reference to your Application No. IND/WB/FES/20192020/70937,dated 22/10/2019, regarding the Fire Safety Certificate IN FAVOUR OF DAV PUBLIC SCHOOL for the occupancy of an existing construction of BLOCK A G + 2 storied building AND BLOCK B G + 2 storied building AND ALSO SINGLE STORIED OFFICE BUILDING under group Educational at the premises no OVER PLOT NO. 29, JL NO. 38,MOUZA- RANGAMETA, PS- SALANPUR, PASCHIM BARDHAMAN., Salanpur PS, Paschim Bardhaman – 713335.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

- 1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
- 2. The interior finish decoration of building made with low flame spread material confirming I.S. specification.
- 3. To eliminate risk of fire hazards, good house keeping both for inside and outside of building shall be strictly maintained.
- 4. Existing electrical wiring of the whole building shall have to be carefully checked for any where and tear in them, particularly lines above false ceiling & ducts.
- 5. The fire check door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.
- 6. A fire control room including a close circuit T.V system preferably will have to be installed which will observe the building.
- 7. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all venerable places of the building.
- 8. Floor numbers and directional sign of escape route shall be displayed prominently.
- 9. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 10. First AID Fire Fighting system shall be provided as per I.S Specification.
- 11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
- 12. Fire License shall have to be obtained for storing and processing with L.P.G and other combustible articles.
- 13. All the employees including the managerial staff shall have adequate knowledge of using fire extinguisher and action to be taken for evaquation of building in case of emergency.
- 14. Violation any of the above recommendations. shall be treated as cancelled as legal action may be taken as per existing F.S. Act & Rules 1950 (Amended up to date).
- 15. The Fire Safety certificate is valid for three year and has to be renewed from the date of issue of this letter.

Signature valid
Digitally signed by NITAI
CHATTOPAL VAY
Date: 2019.10.22 10:43:18 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services